

# SEISMIC TEST REPORT – 17101TR1.0

## MANUFACTURER

LS ELECTRIC CO., LTD

LS Tower, 127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-Do, 14119, Republic of Korea

Contact: Namki Lee - +82-41-550-8585 - nlee@ls-electric.com

## TEST CRITERIA

Testing was performed in accordance with ICC-ES AC156 to the following seismic levels:

Level	S <sub>DS_1</sub> (g)	z/h <sub>1</sub>	S <sub>DS_2</sub> (g)	z/h <sub>2</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
1	2.00	1	2.50	0	3.20	2.40	1.68	0.68

## TEST UNITS

UUT	Description	Mounting	Dimensions (in)			Weight (lb)	Resonant Freq. (Hz)			Max. Level	Test Date
			Depth	Width	Height		F-B	S-S	V		
UUT 1	LSLV0075SP100-2CEND3	Wall	7.1	6.2	29.5	34	N/A	N/A	N/A	1	12/11/2019
UUT 2	LSLV0150H100-4CFN+DI	Wall	9.2	7.1	24.6	24	N/A	N/A	N/A	1	12/11/2019
UUT 3	LSLV0185H100-2CENN+DI	Wall	9.2	8.7	23.0	30	N/A	N/A	N/A	1	12/11/2019
UUT 4	LSLV0300SP100-4CEFD3	Wall	10.0	9.4	44.6	107	N/A	N/A	N/A	1	12/11/2019
UUT 5	LSLV0300H100-4CFN+FL	Wall	8.8	8.7	15.1	21	N/A	N/A	N/A	1	12/11/2019
UUT 6	LSLV0370H100-4CEFD	Wall	11.2	10.8	20.5	60	N/A	N/A	N/A	1	12/11/2019
UUT 7	LSLV0450H100-4COFD	Wall	11.2	12.1	20.1	75	N/A	N/A	N/A	1	12/11/2019
UUT 8	LSLV0550SP100-4CEND3	Wall	12.0	12.9	57.5	182	N/A	N/A	N/A	1	12/11/2019
UUT 9	LSLV0750H100-4COND+FL	Wall	12.8	12.1	21.7	92	N/A	N/A	N/A	1	12/11/2019
UUT 10	LSLV0900H100-4CEND	Wall	12.8	12.1	27.0	104	N/A	N/A	N/A	1	12/11/2019
UUT 11	LSLV0900H100-4CEND+DI	Wall	12.2	12.1	38.6	121	N/A	N/A	N/A	1	12/11/2019

## TESTING LABORATORY

ENVIRONMENTAL TESTING LABORATORY

11034 Indian Trail, Dallas, TX 75229

Contact: Jeremy Lange - 972-247-9657 - jeremy@etldallas.com

Table: 10ft x 10ft Triaxial

## CERTIFICATION COMPANY

MANWILL ENGINEERING LLC

Certifying Engineer: Derek Manwill, SE

California License Number: S6266



Date Signed: 06/23/2023

## TESTING SUMMARY

Each referenced UUT was tested in accordance with the requirements of ICC-ES AC156 and was full of operating content during the shake table test. Each UUT maintained structural integrity and remained functional per manufacturer requirement after the shake table test.

### Test Units

UUT	Description	Mounting	Dimensions (in)			Weight (lb)	Resonant Freq. (Hz)			Max. Level	Test Date
			Depth	Width	Height		F-B	S-S	V		
UUT 1	LSLV0075SP100-2CEND3	Wall	7.1	6.2	29.5	34	N/A	N/A	N/A	1	12/11/2019
UUT 2	LSLV0150H100-4CEFNDI	Wall	9.2	7.1	24.6	24	N/A	N/A	N/A	1	12/11/2019
UUT 3	LSLV0185H100-2CENN+DI	Wall	9.2	8.7	23.0	30	N/A	N/A	N/A	1	12/11/2019
UUT 4	LSLV0300SP100-4CEFD3	Wall	10.0	9.4	44.6	107	N/A	N/A	N/A	1	12/11/2019
UUT 5	LSLV0300H100-4CEFNDI	Wall	8.8	8.7	15.1	21	N/A	N/A	N/A	1	12/11/2019
UUT 6	LSLV0370H100-4CEFD	Wall	11.2	10.8	20.5	60	N/A	N/A	N/A	1	12/11/2019
UUT 7	LSLV0450H100-4COFD	Wall	11.2	12.1	20.1	75	N/A	N/A	N/A	1	12/11/2019
UUT 8	LSLV0550SP100-4CEND3	Wall	12.0	12.9	57.5	182	N/A	N/A	N/A	1	12/11/2019
UUT 9	LSLV0750H100-4COND+FL	Wall	12.8	12.1	21.7	92	N/A	N/A	N/A	1	12/11/2019
UUT 10	LSLV0900H100-4CEND	Wall	12.8	12.1	27.0	104	N/A	N/A	N/A	1	12/11/2019
UUT 11	LSLV0900H100-4CEND+DI	Wall	12.2	12.1	38.6	121	N/A	N/A	N/A	1	12/11/2019

Note: See UUT Summaries for detailed description of UUT mounting. The fixture was isolated and rigid mounted to the table, depending on the test run.

### Test Data

The test levels are listed below:

Level	S <sub>ds_1</sub> (g)	z/h <sub>1</sub>	S <sub>ds_2</sub> (g)	z/h <sub>2</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
1	2.00	1	2.50	0	3.20	2.40	1.68	0.68


The acceleration time histories met the 90% A<sub>RIG</sub> requirement from AC156 as shown below:

Test Run	Date	Level	Description	90% A <sub>RIG</sub> (g)		Peak Table Acceleration (g)		
				Horizontal	Vertical	X	Y	Z
Run 1	12/11/2019	1	UUT 1 to UUT 11 (Rigid)	2.16	0.61	3.00	2.21	1.50
Run 2	12/11/2019	1	UUT 1 to UUT 11 (Isolated)	2.16	0.61	3.16	2.28	1.95


The Test Response Spectra met the Required Response Spectra as allowed by Section 6.5.3 of AC156. Shake table motions in three orthogonal directions were found to be statistically independent. Detailed plots and tabular data can be found in the section for each test run.

**Test Response Spectra vs. Required Response Spectra**

**TRS vs RRS, 5% Damping (Run 1)**



**TRS vs RRS, 5% Damping (Run 2)**



**REVISION HISTORY**

Revision	Date	Revision Description
0	06/23/2023	Initial issue of report.

**TABLE OF CONTENTS**

TESTING SUMMARY .....2

REVISION HISTORY .....4

TEST WITNESSES.....6

SHAKE TABLE INFORMATION .....6

TEST PROCEDURE.....7

UUT SUMMARY .....8

    UUT Summary – UUT 1.....8

    UUT Summary – UUT 2.....9

    UUT Summary – UUT 3.....10

    UUT Summary – UUT 4.....11

    UUT Summary – UUT 5.....12

    UUT Summary – UUT 6.....13

    UUT Summary – UUT 7.....14

    UUT Summary – UUT 8.....15

    UUT Summary – UUT 9.....16

    UUT Summary – UUT 10.....17

    UUT Summary – UUT 11.....18

RUN 1 – Rigid .....19

    Test Pictures .....19

    Test Response Spectra vs. Required Response Spectra Plots .....24

    Test Response Spectra vs. Required Response Spectra Data .....25

    Acceleration Time History Plots.....26

    Statistical Independence of Table Motion Plots.....27

    Unit Accelerometer Output .....28

    Resonant Frequency Search Plots.....32

RUN 2 – Isolated.....36

    Test Pictures .....36

    Test Response Spectra vs. Required Response Spectra Plots .....40

Test Response Spectra vs. Required Response Spectra Data .....41  
Acceleration Time History Plots.....42  
Statistical Independence of Table Motion Plots.....43  
Unit Accelerometer Output .....44  
Resonant Frequency Search Plots .....48  
APPENDIX – LABORATORY ACCREDITATION .....52

## TEST WITNESSES

Jeong-Dae "J.D." – LS Electric Co., Ltd  
 Jeremy Lange, Jeff Lewis – Environmental Testing Laboratory  
 Derek Manwill – Manwill Engineering

## SHAKE TABLE INFORMATION

Table: 10ft x 10ft Triaxial; Displacement: 10in; Maximum Velocity: 75in/sec; Frequency Range: 1-100Hz;  
 Actuators: (6) 24kip; Maximum Acceleration: 7g; Maximum Payload: 20kip.

Environmental Testing Laboratory is accredited to ISO 17025 for the ICC-ES AC156 test standard by the ANSI-ASQ National Accreditation Board. The accreditation certificate is attached to the end of the report. The required equipment was in calibration at the time of testing, as shown in the equipment calibration schedule below.

Lab ID	Ch.	Description	Manufacturer	Model	Cal. Date	Cal. Due
1430	1	Accelerometer	PCB Piezotronics	353B34	6/14/2019	6/14/2020
1431	5	Accelerometer	PCB Piezotronics	353B34	6/15/2019	6/15/2020
1432	9	Accelerometer	PCB Piezotronics	353B34	6/22/2019	6/22/2020
1643	2	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1644	6	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1645	10	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1656	3	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1657	7	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1658	11	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1653	4	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1654	8	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1655	12	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1635	13	Accelerometer	PCB Piezotronics	355B03	3/15/2019	3/15/2020
1636	14	Accelerometer	PCB Piezotronics	355B03	3/15/2019	3/15/2020
1637	15	Accelerometer	PCB Piezotronics	355B03	3/15/2019	3/15/2020
1650	16	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1651	17	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1652	18	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1640	19	Accelerometer	PCB Piezotronics	355B03	3/15/2019	3/15/2020
1641	20	Accelerometer	PCB Piezotronics	355B03	3/15/2019	3/15/2020
1642	21	Accelerometer	PCB Piezotronics	355B03	3/15/2019	3/15/2020
1631	22	Accelerometer	PCB Piezotronics	355B03	3/8/2019	3/8/2020
1632	23	Accelerometer	PCB Piezotronics	355B03	3/8/2019	3/8/2020
1634	24	Accelerometer	PCB Piezotronics	355B03	3/15/2019	3/15/2020
1646	25	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1647	26	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1648	27	Accelerometer	PCB Piezotronics	355B03	3/29/2019	3/29/2020
1629	28	Accelerometer	PCB Piezotronics	355B03	2/5/2019	2/5/2020
1630	29	Accelerometer	PCB Piezotronics	355B03	2/5/2019	2/5/2020
1631	30	Accelerometer	PCB Piezotronics	355B03	3/8/2019	3/8/2020
1416	N/A	Vibration Controller	Vibration Research	VR9500 Revolution	5/8/2019	5/8/2020
1417	N/A	Vibration Controller	Vibration Research	VR9500 Revolution	5/8/2019	5/8/2020
1418	N/A	Vibration Controller	Vibration Research	VR9500 Revolution	5/6/2019	5/6/2020
1419	N/A	Vibration Controller	Vibration Research	VR9500 Revolution	5/3/2019	5/3/2020
1420	N/A	Vibration Controller	Vibration Research	VR9500 Revolution	5/3/2019	5/3/2020
1421	N/A	Vibration Controller	Vibration Research	VR9500 Revolution	5/2/2019	5/2/2020
1422	N/A	Vibration Controller	Vibration Research	VR9500 Revolution	5/2/2019	5/2/2020

## TEST PROCEDURE

The following test procedure was implemented in accordance with ICC-ES AC156. Detailed photographs and plots can be found in the section for each test run.

### Pre-Test Inspection, Weighing, and Measuring

Upon arrival at the lab, each UUT was visually examined for structural damage from transport and lifting. No visible damage was observed. Photographs of the pre-test condition are included in the section for each test run. Each UUT was weighed and measured at the test laboratory. The results can be found in the “UUT Summary” table at the beginning of this report.

### Pre-Test Functional Verification

Functional testing was performed by the manufacturer at the test laboratory prior to performing the multi-frequency seismic simulation test. The functional test included powering the drives, ensuring all internal components operated, and running a motor from the drive. Each UUT passed the functional tests.

### Mounting

Each UUT was mounted to the test fixture as described in the footnotes of the “UUT Summary” table at the beginning of this report. The fixture was isolated and rigid mounted to the table, depending on the test run, as described in the footnotes of the “UUT Summary” table at the beginning of this report.

### Monitoring

Reference control accelerometers were located on the shake table. These accelerometers were used to determine the shake table motions and compliance with the requirements of ICC-ES AC156. Accelerometers were located on each UUT. Photographs of the accelerometer placement are included in the section for each test run.

### Resonant Frequency Search

A resonant frequency search was performed prior to performing the multi-frequency seismic simulation test. The search was a  $0.1g \pm 0.05g$  sine sweep from 1.3 to 50Hz at two octaves per minute. Transmissibility plots can be found in the section for each test run.

### Multi-Frequency Seismic Simulation Test

Each UUT was subjected to a multi-frequency seismic simulation test with the parameters shown in the “Test Data” section at the beginning of this report. The input motion was approximately 30 seconds long with at least 20 seconds of strong motion. The plots of TRS vs. RRS, Acceleration Time History, Coherence, and Cross Correlation can be found in the section for each test run.

### Post-Test Inspection

After the multi-frequency seismic simulation test, each UUT was visually examined. No visible damage was observed. Photographs of the post-test condition are included in the section for each test run.

### Post-Test Functional Verification

Functional testing was performed by the manufacturer at the test laboratory after performing the multi-frequency seismic simulation test. The post-test functional verification was identical to the pre-test functional verification listed above. Each UUT passed the functional tests.

## UUT SUMMARY



### UUT Summary – UUT 1

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0075SP100-2CEND3

**Dimensions:** Depth=7.1-in, Width=6.2-in, Height=29.5-in, Weight=34-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) #10 wood screws. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** LS Electric - capacitor PCB (10120003821), Metasol - contactor (13370032), Kosed - DC reactors (22910000874), LS Electric - manual motor starter (7051051), Wabash - transformer (73016296006), LS Electric - power PCB (10120004554), LS Electric - OL detector (38060134), Honeywell - thermal overload device (6110000126), Osada - terminal block (10060001237), LS Electric - auxiliary contact (83361634001), LS Electric - interlock unit (83411634001), Fuji - PIM/IGBT (8910000851), LS Electric - main power assembly (10120004554), LS Electric - input PCB (10120003803), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294114), DCC - fan (7760000244), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 2

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0150H100-4CEFN+DI

**Dimensions:** Depth=9.2-in, Width=7.1-in, Height=24.6-in, Weight=24-lb

**Resonant Frequencies:** F-B=N/A , S-S=N/A , V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (6) #10 wood screws. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** LS Electric - disconnect modules (64160044), LS Electric - capacitor PCB (10120003826), LS Electric - circuit breaker (02070354UL), LS Electric - power PCB (10120004561), Infineon - PIM/IGBT (08910000856), LS Electric - main power assembly (10120004561), LS Electric - input PCB (10120003807), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294117), Nidec - fan (7760000299), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)



### UUT Summary – UUT 3

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0185H100-2CENN+DI

**Dimensions:** Depth=9.2-in, Width=8.7-in, Height=23.0-in, Weight=30-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (6) #10 wood screws. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** LS Electric - disconnect modules (64160036), LS Electric - capacitor PCB (10120003827), LS Electric - manual motor starter (7070019), LS Electric - power PCB (10120004557), Fuji - PIM/IGBT (8910000853), LS Electric - main power assembly (10120004557), LS Electric - input PCB (10120003805), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294120), Nidec - fan (7760000172), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 4

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0300SP100-4CEFD3

**Dimensions:** Depth=10.0-in, Width=9.4-in, Height=44.6-in, Weight=107-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A


**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) #10 wood screws. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** LS Electric - capacitor PCB (10120003831), Metasol - contactor (13620002), Kosed - DC reactors (22910000889), LS Electric - circuit breaker (02070368UL), Wabash - transformer (73016296006), LS Electric - power PCB (10120004564), LS Electric - OL detector (38060132), Honeywell - thermal overload device (6110000126), Osada - terminal block (10060001237), LS Electric - auxiliary contact (83361634001), LS Electric - interlock unit (83411634001), Infineon - PIM/IGBT (08910000858), LS Electric - main power assembly (10120004564), LS Electric - input PCB (10120003808), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294120), Nidec - fan (7760000172), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)



### UUT Summary – UUT 5

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0300H100-4CEFN+FL

**Dimensions:** Depth=8.8-in, Width=8.7-in, Height=15.1-in, Weight=21-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) #10 wood screws. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** LS Electric - capacitor PCB (10120003831), LS Electric - power PCB (10120004564), Infineon - PIM/IGBT (08910000858), LS Electric - main power assembly (11040002616), LS Electric - input PCB (10120003808), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294120), Nidec - fan (7760000172), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 6

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0370H100-4CEFD

**Dimensions:** Depth=11.2-in, Width=10.8-in, Height=20.5-in, Weight=60-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) 1/4-in lag bolts. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** Kosed - DC reactors (22910000751), Huawei - main capacitor (08810002700), LS Electric - EMC filter (9710000540), LS Electric - power PCB (10120004346), Fuji - PIM/IGBT (8910001102), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004566), LS Electric - snubber PCB (10120004347), Sanrex - diode module (08960001322), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294123), LS Electric - terminal block (62776224001), Nidec - fan (7760000172), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224001), LS Electric - busbar (70226224035, 70226224037, 70226225012), LS Electric - busbar diode (70216225048), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 7

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0450H100-4COFD

**Dimensions:** Depth=11.2-in, Width=12.1-in, Height=20.1-in, Weight=75-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) 1/4-in lag bolts. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** Kosed - DC reactors (22910000752), Huawei - main capacitor (08810002699), LS Electric - EMC filter (9710000541), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004567), LS Electric - gate drive (10120006332), LS Electric - CT PCB (10120004349), LS Electric - snubber PCB (10120004347), Sanrex - diode module (08960001322), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294126), LS Electric - terminal block (62776224004), Nidec - fan (7760000172), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224002), LS Electric - busbar (70226224038, 70226224039), LS Electric - busbar diode (70216225048), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 8

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0550SP100-4CEND3

**Dimensions:** Depth=12.0-in, Width=12.9-in, Height=57.5-in, Weight=182-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) 5/16-in lag bolts. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** Metasol - contactor (13640002), Kosed - DC reactors (22910000753), Huawei - main capacitor (08810002701), LS Electric - circuit breaker (02070369UL), Wabash - transformer (73016296006), LS Electric - OL detector (38060132), Honeywell - thermal overload device (6110000126), Osada - terminal block (10060002056), LS Electric - auxiliary contact (83361634001), LS Electric - interlock unit (83411634001), Fuji - PIM/IGBT (8910001101), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004568), LS Electric - gate drive (10120006332), LS Electric - CT PCB (10120004361), LS Electric - snubber PCB (10120004347), Sanrex - diode module (08960001323), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294126), LS Electric - terminal block (62776224002), Nidec - fan (7760000172), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224004), LS Electric - busbar (70226224038, 70226224039), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 9

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0750H100-4COND+FL

**Dimensions:** Depth=12.8-in, Width=12.1-in, Height=21.7-in, Weight=92-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) 5/16-in lag bolts. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** Kosed - DC reactors (22910000754), Huawei - main capacitor (08810002700), Fuji - PIM/IGBT (8910001101), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004569), LS Electric - gate drive (10120006332), LS Electric - snubber PCB (10120004353), LS Electric - fan SMPS (10120004352), Sanrex - diode module (08960001321), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294129), LS Electric - terminal block (62776224003), NMB - fan (7760000272), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224003), LS Electric - busbar (70226224040), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 10

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0900H100-4CEND

**Dimensions:** Depth=12.8-in, Width=12.1-in, Height=27.0-in, Weight=104-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (4) 5/16-in lag bolts. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** Kosed - DC reactors (22910000755), Huawei - main capacitor (08810002699), Fuji - PIM/IGBT (8910001100), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004580), LS Electric - gate drive (10120006333), LS Electric - snubber PCB (10120004353), LS Electric - fan SMPS (10120004352), Sanrex - diode module (08960001321), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294129), LS Electric - terminal block (62776224005), NMB - fan (7760000272), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224005), LS Electric - busbar (70226224040), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)



## UUT Summary – UUT 11

**Manufacturer:** LS Electric Co., Ltd, **Model:** LSLV0900H100-4CEND+DI

**Dimensions:** Depth=12.2-in, Width=12.1-in, Height=38.6-in, Weight=121-lb

**Resonant Frequencies:** F-B=N/A, S-S=N/A, V=N/A

**Importance Factor,  $I_P=1.5$ :** Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Wall mounted using (6) 5/16-in lag bolts. For Rigid run, the test fixture was rigid mounted to the table. For Isolated run, the test fixture was mounted to table using (4) Mason SSLFHC spring isolators.


**Construction:** Carbon steel and plastic construction.

**Testing Notes:** None.

**Subcomponents:** LS Electric - disconnect modules (64160052), Kosed - DC reactors (22910000755), Huawei - main capacitor (08810002699), LS Electric - circuit breaker (02090228UL), Fuji - PIM/IGBT (8910001100), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004580), LS Electric - gate drive (10120006333), LS Electric - snubber PCB (10120004353), LS Electric - fan SMPS (10120004352), Sanrex - diode module (08960001321), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294129), LS Electric - terminal block (62776224005), NMB - fan (7760000272), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224005), LS Electric - busbar (70226224040), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)

**RUN 1 – Rigid**

The rigid run was performed to Level 1 as shown in the “Test Data” section at the beginning of this report. This section provides detailed photographs and plots from the testing.




**Test Pictures**



Pre-test UUT 1




Pre-test UUT 2



Pre-test UUT 3



Pre-test UUT 4



Pre-test UUT 5



Pre-test UUT 6




Pre-test UUT 7



Pre-test UUT 8



Pre-test UUT 9



Pre-test UUT 10



Pre-test UUT 11



Pre-test




Pre-test fixture anchorage



Pre-test fixture



Accelerometer UUT 3  
X/FB=Ch3, Y/SS=Ch7, Z/V=Ch11



Accelerometer UUT 8  
X/FB=Ch4, Y/SS=Ch8, Z/V=Ch12



Accelerometer UUT 10  
X/FB=Ch13, Y/SS=Ch14, Z/V=Ch15



Accelerometer UUT 11  
X/FB=Ch16, Y/SS=Ch17, Z/V=Ch18



Post-test



Post-test






Post-test



Post-test

**Test Response Spectra vs. Required Response Spectra Plots**






**Test Response Spectra vs. Required Response Spectra Data**

The tabular data used to create the previous TRS vs. RRS plots is as follows:



X Direction			Y Direction			Z Direction		
Freq. (Hz)	RRS (g)	TRS (g)	Freq. (Hz)	RRS (g)	TRS (g)	Freq. (Hz)	RRS (g)	TRS (g)
1.21	3.00	2.29	1.20	2.98	2.26	1.29	1.67	1.76
1.36	3.20	3.35	1.35	3.20	3.88	1.45	1.68	1.76
1.52	3.20	3.41	1.51	3.20	3.47	1.63	1.68	1.86
1.71	3.20	3.76	1.70	3.20	3.19	1.83	1.68	1.73
1.92	3.20	3.09	1.90	3.20	3.75	2.06	1.68	2.02
2.16	3.20	3.59	2.14	3.20	3.37	2.31	1.68	1.68
2.42	3.20	3.55	2.40	3.20	3.30	2.59	1.68	1.66
2.72	3.20	3.78	2.69	3.20	3.32	2.91	1.68	1.84
3.05	3.20	3.90	3.02	3.20	3.51	3.26	1.68	2.14
3.42	3.20	3.92	3.39	3.20	3.44	3.66	1.68	1.85
3.84	3.20	3.88	3.81	3.20	3.56	4.11	1.68	1.95
4.31	3.20	3.74	4.27	3.20	3.13	4.61	1.68	1.73
4.84	3.20	3.97	4.79	3.20	3.53	5.18	1.68	1.93
5.43	3.20	4.10	5.38	3.20	3.83	5.81	1.68	2.26
6.10	3.20	3.77	6.04	3.20	3.40	6.52	1.68	2.90
6.85	3.20	4.26	6.78	3.20	3.45	7.32	1.68	3.89
7.68	3.20	5.52	7.61	3.20	4.27	8.22	1.68	3.77
8.63	3.17	4.71	8.54	3.18	4.26	9.23	1.56	3.94
9.68	3.10	7.07	9.59	3.11	4.64	10.36	1.45	4.96
10.87	3.03	7.16	10.76	3.03	4.25	11.63	1.34	5.17
12.20	2.95	6.12	12.08	2.96	5.82	13.05	1.25	5.15
13.69	2.88	4.67	13.56	2.89	5.04	14.65	1.16	4.47
15.37	2.82	3.53	15.22	2.82	3.45	16.44	1.07	4.28
17.25	2.75	4.04	17.09	2.76	2.97	18.45	0.99	3.23
19.36	2.69	5.13	19.18	2.69	2.90	20.71	0.92	2.91
21.74	2.62	5.11	21.53	2.63	2.70	23.25	0.85	2.69
24.40	2.56	5.12	24.16	2.56	2.83	26.10	0.79	2.47
27.38	2.50	6.16	27.12	2.50	3.30	29.29	0.73	2.69
30.74	2.44	4.32	30.44	2.44	3.13	32.88	0.68	2.48
34.50	2.40	3.53	34.17	2.40	2.73	36.91	0.68	2.27

As is shown in the “Resonant Frequency Search Plots” section below, no resonance response phenomena exist below 5Hz. Therefore, per ICC-ES AC156 Section 6.5.3.1.1, the TRS is only required to envelop the RRS down to 3.5Hz. Any TRS points that fall below the RRS (above the cutoff frequency) are highlighted above. The TRS meets all requirements from ICC-ES AC156 Section 6.5.3.





**Acceleration Time History Plots**











**Statistical Independence of Table Motion Plots**







**Unit Accelerometer Output**





















**Resonant Frequency Search Plots**









## RUN 2 – Isolated

The isolated run was performed to Level 1 as shown in the “Test Data” section at the beginning of this report. This section provides detailed photographs and plots from the testing.



## Test Pictures




Pre-test



Pre-test



Pre-test fixture



Pre-test isolator mounting



Post-test



Post-test



Post-test



Post-test




Post-test



Post-test UUT 1



Post-test UUT 2



Post-test UUT 3



Post-test UUT 4



Post-test UUT 5



Post-test UUT 6



Post-test UUT 7



Post-test UUT 8



Post-test UUT 9






Post-test UUT 10



Post-test UUT 11

**Test Response Spectra vs. Required Response Spectra Plots**






**Test Response Spectra vs. Required Response Spectra Data**

The tabular data used to create the previous TRS vs. RRS plots is as follows:



X Direction			Y Direction			Z Direction		
Freq. (Hz)	RRS (g)	TRS (g)	Freq. (Hz)	RRS (g)	TRS (g)	Freq. (Hz)	RRS (g)	TRS (g)
1.19	2.95	1.99	1.28	3.16	3.12	1.26	1.63	1.58
1.33	3.20	3.31	1.44	3.20	3.51	1.41	1.68	1.86
1.50	3.20	3.52	1.62	3.20	3.72	1.58	1.68	1.81
1.68	3.20	3.73	1.81	3.20	3.66	1.78	1.68	1.82
1.88	3.20	3.19	2.04	3.20	3.54	2.00	1.68	1.84
2.12	3.20	3.69	2.28	3.20	3.63	2.24	1.68	1.78
2.37	3.20	3.60	2.56	3.20	3.46	2.52	1.68	1.82
2.67	3.20	3.71	2.88	3.20	3.40	2.82	1.68	1.83
2.99	3.20	3.79	3.23	3.20	3.43	3.17	1.68	2.22
3.36	3.20	3.53	3.63	3.20	3.43	3.56	1.68	2.12
3.77	3.20	3.96	4.07	3.20	3.17	3.99	1.68	2.45
4.23	3.20	3.57	4.57	3.20	3.53	4.48	1.68	2.11
4.75	3.20	3.62	5.13	3.20	3.61	5.03	1.68	2.08
5.33	3.20	4.01	5.76	3.20	3.45	5.65	1.68	1.99
5.98	3.20	3.60	6.46	3.20	3.42	6.34	1.68	2.31
6.72	3.20	4.08	7.25	3.20	3.26	7.11	1.68	2.49
7.54	3.20	4.33	8.14	3.20	4.32	7.99	1.68	2.73
8.46	3.19	3.89	9.14	3.14	3.98	8.96	1.59	2.91
9.50	3.11	4.72	10.26	3.06	3.83	10.06	1.48	3.68
10.66	3.04	4.53	11.51	2.99	4.15	11.29	1.37	4.70
11.97	2.97	6.53	12.92	2.92	4.52	12.68	1.27	5.11
13.43	2.90	5.95	14.51	2.85	4.46	14.23	1.18	5.02
15.08	2.83	4.46	16.28	2.78	4.27	15.97	1.09	5.08
16.92	2.76	4.90	18.28	2.72	3.95	17.93	1.01	4.23
18.99	2.70	4.68	20.52	2.65	4.24	20.12	0.94	4.27
21.32	2.63	5.21	23.03	2.59	3.64	22.59	0.87	3.97
23.93	2.57	5.30	25.85	2.53	3.90	25.35	0.81	4.02
26.86	2.51	5.93	29.01	2.47	3.67	28.46	0.75	4.11
30.15	2.45	4.58	32.57	2.41	3.42	31.94	0.69	3.63
33.84	2.40	4.97	36.55	2.40	3.15	35.86	0.68	3.03

As is shown in the “Resonant Frequency Search Plots” section below, no resonance response phenomena exist below 2.4Hz. Therefore, per ICC-ES AC156 Section 6.5.3.1.1, the TRS is only required to envelop the RRS down to 1.8Hz. Any TRS points that fall below the RRS (above the cutoff frequency) are highlighted above. The TRS meets all requirements from ICC-ES AC156 Section 6.5.3.





**Acceleration Time History Plots**











**Statistical Independence of Table Motion Plots**







**Unit Accelerometer Output**





















## Resonant Frequency Search Plots









## APPENDIX – LABORATORY ACCREDITATION



# CERTIFICATE OF ACCREDITATION

## ANSI National Accreditation Board

11617 Coldwater Road, Fort Wayne, IN 46845 USA

This is to certify that

**Environmental Testing Laboratory**  
**11034 Indian Trail**  
**Dallas, TX 75229**

has been assessed by ANAB and meets the requirements of international standard

## ISO/IEC 17025:2017

while demonstrating technical competence in the field of

## TESTING

Refer to the accompanying Scope of Accreditation for information regarding the types of activities to which this accreditation applies

AT-1787

Certificate Number

  
ANAB Approval

Certificate Valid Through: 05/24/2021  
Version No. 005 Issued: 04/24/2019



This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated April 2017).



# ANSI National Accreditation Board

## SCOPE OF ACCREDITATION TO ISO/IEC 17025:2017

### Environmental Testing Laboratory

11034 Indian Trail

Dallas, Texas 75229

Jeremy Lange 972-247-9657

Jeremy@etldallas.com www.etldallas.com

### TESTING

Valid to: **May 24, 2021**

Certificate Number: **AT-1787**

#### Mechanical

Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Temperature, Temperature Shock	ASTM Specifications GR-63-CORE Specifications GR-487-CORE Specifications IEC Specifications ISO Specifications ISTA Specifications MIL-Standards Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	Interior Components Exterior Components	HP Data Acquisition Various Size Chambers
Altitude, Decompression, Overpressure	ASTM Specifications IEC Specifications MIL-Standard Specifications RTCA/DO-160 Telcordia GR-63-CORE Telcordia GR-487-CORE UL 50E Customer Supplied Procedure	Interior Components Exterior Components	HP Data Acquisition Various Size Chambers
Humidity	ASTM Specifications GR-63-CORE Specifications GR-487-CORE Specifications IEC Specifications ISO Specifications ISTA Specifications MIL-Standard Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	Interior Components Exterior Components Cabinets	HP Data Acquisition Various Size Chambers



# ANSI National Accreditation Board

## Mechanical

Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Earthquake Resistance, Seismic	GR-487-CORE Specifications GR-63-CORE Specifications ICC ES AC156 Seismic Specifications, IEEE Standard Specifications Customer Supplied Procedure	Interior Components Rack, Enclosures	32 Channel Controller ANCO Shake Table
Solar Testing	MIL-Standard Specifications RTCA /DO-160 Specifications ASTM G154 Customer Supplied Procedure	Plastics, Metals, Exterior Components	HP Data Acquisition Various Size Chambers
Rain	DIN 40 050 Specifications IEC 60529 Specifications ISO 20653 Specifications MIL- Standard Specifications NEMA 250 Specifications RTCA/DO-160 Specifications Telcordia GR-487-CORE Telcordia GR-63-CORE UL 50E Customer Supplied Procedure	External Components, Racks, Outdoor Products	Various Nozzles Calibrated Flow Meters
Immersion	IEC 60529 MIL-STD Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	External Components	Pressure Vessel Calibrated Flow Meter or Water Column
Sand and Dust	GR-487-CORE Specifications GR-63-CORE Specifications IEC 60529 MIL-Standard Specifications NEMA 250 Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	Metals, Plastics, Rubbers, External Components	Sand & Dust Chambers HP Data Acquisition Anemometer
Explosive Atmosphere	MIL-Standard Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	Internal Components, Electronics	Explosive Atmosphere Chamber N-Hexane or 100 LL HP Data Acquisition
Acceleration	MIL-Standard Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	Aircraft Hardware, Military Hardware	10 foot Centrifuge 200lbs at 200g
Icing Test	MIL-Standard Specifications IEEE C37.30.1-200X D1 Customer Supplied Procedure	External Components	Water Chiller for 33°F Water Various Size Chambers HP Data Acquisition



# ANSI National Accreditation Board

## Mechanical

Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Drop Test (Packaged and Un-Packaged)	ASTM Specifications GR-487-CORE Specifications GR-63-CORE Specifications IEC Specifications ISTA Specifications Customer Supplied Procedure	Pallet Packaged, Container Packaged	L.A.B. Drop Tester Multiple Quick Releases
Mechanical Load Test	ASTM Specifications GR-487-CORE Specifications GR-63-CORE Specifications IEC Specifications ISTA Specifications Customer Supplied Procedure	Metal, Alloys, Fasteners, Doors	10 ton press Load Cells (5k, 10k, 100k) lb
Contamination by Fluids	MIL-Standard Specifications RTCA /DO-160 Specifications Customer Supplied Procedure	Rubbers, Plastics, Exterior Components	Various Fluids
Fungus Exposure	MIL STD 810G Sec 508.6 RTCA/DO-160 Specifications Customer Supplied Procedure	Interior Components Exterior Components	HP Data Acquisition Various Size Chambers
Mechanical Shock	ASTM Specifications GR-487-CORE Specifications GR-63-CORE Specifications IEC Specifications ISO Specifications ISTA Specifications MIL-Standards Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	Interior Components Exterior Components	Unholtz Dickie Shakers Vibration Research Controllers Dactron Controllers
Vibration (Sine, Random, SRS, Shock)	ASTM Specifications ETS 300 0019-1-2 Specifications GR-487-CORE Specifications GR-63-CORE Specifications IEC Specifications IEEE Specifications ISTA Specifications MIL-Standard Specifications RTCA/DO-160 Specifications Customer Supplied Procedure	Interior Components Exterior Components	Unholtz Dickie Shakers L.A.B. Transportation Simulator Vibration Research Controllers Dactron Controllers
Salt Fog/Spray	ASTM B 117 MIL-STD Specifications RTCA/DO-160 Specifications	Metals, Alloys	Salt Fog Chamber Customer Set-ups



**Mechanical**

<b>Specific Tests and/or Properties Measured</b>	<b>Specification, Standard, Method, or Test Technique</b>	<b>Items, Materials or Product Tested</b>	<b>Key Equipment or Technology</b>
Body Structure Load Test	AMD 001 NFPA 1917, Section 9.1 SAE J3057	Ambulance	Hydraulic Fixture Loads up to 60 000 lb
Body Door Retention Load Test	AMD 002 NFPA 1917, Section 9.2	Ambulance	Load Cell Loads up to 3 500 lb
Tank Retention Load Test	AMD 003 NFPA 1917, Section 9.3	Ambulance	Load Cell Loads up to 3 500 lb
Litter Retention Load Test	AMD 004 NFPA 1917, Section 9.4 SAE J3102	Ambulance	Custom Fixture with load cell, loads up to 3 500 lb
12 volt DC Electrical System Test	AMD 005 NFPA 1917, Section 9.5	Ambulance	Calibrated Multi-Meter
Sound Level Test	AMD 006 NFPA 1917, Section 9.6	Ambulance	Sound Meter
Carbon Monoxide Level Test	AMD 007 NFPA 1917, Section 9.7	Ambulance	CO Monitor 0.5 ppm Accuracy
Grab Rail Load Test	AMD 008 NFPA 1917, Section 9.8	Ambulance	Load Cell Loads up to 1 000 lb
125 Volt AC Electrical System Test	AMD 009 NFPA 1917, Section 9.9	Ambulance	Calibrated Multi-Meter
Water Spray	AMD 010 NFPA 1917, Section 9.10	Ambulance	Water Spray Apparatus per AMD
Equipment Temperature Test	AMD 011 NFPA 1917, Section 9.11	Ambulance	HP Data Acquisition System -30 °F to 140 °F
Interior Climate Control Test	AMD 012 NFPA 1917, Section 9.12	Ambulance	HP Data Acquisition System -30 °F to 140 °F
Weight Distribution / Center of Gravity	AMD 013 NFPA 1917, Section 9.13	Ambulance	4 Vehicle Wheel Scales Up to 10 000 per scale Accurate to 5 lb
Engine Cooling Test	AMD 014 NFPA 1917, Section 9.14	Ambulance	HP Data Acquisition System -30 °F to 140 °F
Main Oxygen System Test	AMD 015 NFPA 1917, Section 9.15	Ambulance	Calibrated Pressure Gauge Gas Flow Meter
Patient Lighting Test	AMD 016 NFPA 1917, Section 9.16	Ambulance	Calibrated Light Meter
Road Test	AMD 017 NFPA 1917, Section 9.17	Ambulance	Test per AMD
Step / Bumper Load Test	AMD 018 NFPA 1917, Section 9.18	Ambulance	Hand-Truck and Scale
Storage Measuring	AMD 019 NFPA 1917, Section 9.19	Ambulance	Calibrated tape measure



# ANSI National Accreditation Board

## Mechanical

Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Floor Distribution Load Test	AMD 020 NFPA 1917, Section 9.20	Ambulance	Hand-Truck Deflection Indicator per AMD
Aspirator System Test	AMD 021 NFPA 1917, Section 9.21	Ambulance	Gas Flow Meter Vacuum Gauge
Cold Engine Start Test	AMD 022 NFPA 1917, Section 9.22	Ambulance	HP Data Acquisition System -30 °F to 140 °F
Perimeter Illumination Test	AMD 024 NFPA 1917, Section 9.24	Ambulance	Calibrated Light Meter
Occupant Head Clearance	AMD 025 NFPA 1917, Section 9.25	Ambulance	Test Fixture per AMD
Line Voltage Test	AMD 027 NFPA 1917, Section 8	Ambulance	Volt Meter Amp Meter
Interior Storage Compartment Integrity	SAE J3058	Ambulance	Lead Weights Calibrated Weighing Terminal
Occupant Restraint – Front, Rear, and Side Impact	SAE J2917 SAE J2956 SAE J3044 FMVSS 571.210	Ambulance	Load Cell Loads up to 25,000 lbf
Seat Belt Assemblies Testing	FMVSS 571.209 Customer Supplied Procedure	Occupant Restraint Assemblies	Load Cell

- Note:
1. This scope is formatted as part of a single document including Certificate of Accreditation No. AT-1787.
  2. General identified Standards and Specifications in the above scope that do not have specific document numbers (i.e., ASTM, IEC, ISO, ISTA, MIL STD, and IEEE specifications) are identified of having several documents that provide specifications for a particular test.

Vice President